

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PUB25 NOV0001

Dated: 12/11/2025

It is certified that an inspection team headed by V VENKATESH MURTHY

(Name of Officers with designation) from ASSISTANT EXECUTIVE ENGINEER PHED/RDUSD

inspected the RASHTROTTHANA VIDYA KENDRA CHERKADI BRAHMAYARA

(Name & Address of the school) on 12/11/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. PUB25 NOV0001 dated 12/11/2025

of UDUPI DISTRICT WATER TESTING LAB (PHED Lab) certified that the

RASHTROTTHANA VIDYA KENDRA (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 12/05/2026

Signature with Seal: V Venkatesh Murthy  
Name : V. VENKATESH MURTHY  
Designation : ASSISTANT EXECUTIVE ENGINEER  
Name & Address of the Office / Department : O/O RDUSD

UDUPI SUBDIVISION BANNARJE  
UDUPI-576101

To  
RASHTROTTHANA VIDYA KENDRA  
CHERKADI BRAHMAYARA  
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

V. Venkatesh Murthy  
**PRINCIPAL**  
**Rashtrrothana Vidya Kendra**  
**Cherkadi Village, Brahmavara Taluk,**  
**Udupi District, Karnataka 576215**

V. Venkatesh Murthy  
**CORRESPONDENT**  
**Rashtrrothana Vidya Kendra**  
**Cherkadi Village, Brahmavara Taluk**  
**Udupi District, Karnataka-576215**



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK  
Udupi District Water Testing Laboratory, 1<sup>ST</sup> Floor, Old Zillapanchayath Building, Bannanje, Udupi-576101

**TEST REPORT**

**Address : Rashtrottana Vidya Kendra  
Rani Abbakka Road, Cherkady  
Brahmavara Taluk, Udupi -576215**

Report date: 12.11.2025  
Reference: Test Request form  
Sample receipt date: 10.11.2025  
Sample code: PUB25NOV0001  
Date of Sample collection: 10.11.2025  
Analysis start date: 11.11.2025  
Analysis completion date: 11.11.2025  
Sample collection protocol: NA

Sample Particulars: RO Water (Drinking Water)

Sample quantity: 1 liter

Sl.No	Test	Results	Acceptable Limit IS 10500 :2012	Permissible Limit IS 10500 : 2012	Protocol
<b>Description: Colourless liquid</b>					
1.	pH Value @25°C	6.54	6.5 – 8.5	No relaxation	IS 3025 (Part-11) :2022
2.	Specific Conductance, µS/cm@25°C	164.9	NA	NA	IS 3025 (Part-14) :2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Colour, Hazen Units	1	5	15	IS 3025 (Part-4) :2021
5.	Turbidity, NTU	< 0.5	1	5	IS 3025 (Part-10) : 1984
6.	Total Dissolved Solids , mg/l	82	500	2000	IS 3025 (Part-16) : 2023
7.	Alkalinity as CaCO <sub>3</sub> , mg/l	< 20	200	600	IS 3025 (Part-23) : 2023
8.	Total Hardness as CaCO <sub>3</sub> , mg/l	< 20	200	600	IS 3025 (Part-21) : 2009
9.	Calcium as Ca, mg/l	< 8	75	200	IS 3025 (Part-40) : 2024
10.	Magnesium as Mg, mg/l	< 5	30	100	IS 3025 (Part-46) : 2023
11.	Chloride as Cl, mg/l	45.66	250	1000	IS 3025 (Part-32) : 1988
12.	Sulphate as SO <sub>4</sub> , mg/l	< 1	200	400	IS 3025 (Part-24) : 2022
13.	Fluoride as F, mg/l	0.72	1	1.5	APHA 24 <sup>th</sup> Edition
14.	Nitrate as NO <sub>3</sub> , mg/l	< 0.5	45	No relaxation	APHA 24 <sup>th</sup> Edition
15.	Iron as Fe, mg/l	< 0.1	1	No relaxation	IS 3025 (Part-53) : 2024

Remarks: The above tested parameters are within the acceptable limit as per IS 10500:2012 drinking water specification.

(Nagaveni K.V , Technical Manager)  
Authorized Signatory

RDWSD/WQMSP/TcR/01

**Note:**

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rules applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

**PRINCIPAL**

Rashtrottana Vidya Kendra  
Cherkadi Village, Brahmavara Taluk,  
Udupi District, Karnataka 576215

-----END OF REPORT-----

**CORRESPONDENT**

Rashtrottana Vidya Kendra  
Cherkadi Village, Brahmavara Taluk  
Udupi District, Karnataka-576215