

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PUB 26 MAY 0001

Dated: 14-05-2026

It is certified that an inspection team headed by

MOHAMMED SAALIM (Name of Officers with designation)

from ASSISTANT ENGINEER PHED / RDWSD

inspected the RASHTROTHANA VIDYA KENDRA, CHERKADY BRAHMAVARA

(Name & Address of the school) on 14-05-2026 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. PUB 26 MAY 0001

dated 14-05-2026 of UDUPP DISTRICT WATER TESTING LAB (PHED Lab)

certified that the

RASHTROTHANA VIDYA KENDRA (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains

the hygienic sanitation condition in the school building & the campus as per norms

prescribed by the Central/ State/ U.T. Govt.


This certificate is valid till 13-11-2026.


ASSISTANT ENGINEER
RURAL DRINKING WATER AND SANITATION
SUB DIVISION, UDUPI - 576 101


Signature with Seal: MOHAMMED SAALIM
Name : MOHAMMED SAALIM
Designation : ASSISTANT ENGINEER
Name & Address of the Office / Department %o RDWSD
UDUPP SUBDIVISION BANNARISE UDUPP

To RASHTROTHANA VIDYA KENDRA
CHERKADY BRAHMAVARA
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


PRINCIPAL
Rashtrrothana Vidya Kendra
Cherkadi Village, Brahmavara Taluk,
Udupi District, Karnataka 576215


CORRESPONDENT
Rashtrrothana Vidya Kendra
Cherkadi Village, Brahmavara Taluk
Udupi District, Karnataka-576215



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Udupi District Water Testing Laboratory, 1ST Floor, Old Zillapanchayath Building, Bannanje, Udupi-576101

TEST REPORT

Address : Rashtrottana Vidya Kendra Rani Abbakka Road,Cherkady Brahmavara Taluk, Udupi -576215				Report date: 13.05.2026	
				Reference: Test Request form	
				Sample receipt date: 11.05.2026	
				Sample code: PUB26MAY0001	
				Date of Sample collection: 11.05.2026	
				Analysis start date: 12.05.2026	
				Analysis completion date: 12.05.2026	
Sample collection protocol: NA					
Sample quantity: 1 liter					
Sample Particulars: RO Water (Drinking Water)					
Sl.No	Test	Results	Acceptable Limit IS 10500 :2012	Permissible Limit IS 10500 : 2012	Protocol
Description: Colourless liquid					
1.	pH Value @25°C	6.56	6.5 – 8.5	No relaxation	IS 3025 (Part-11) :2022
2.	Specific Conductance, µS/cm@25°C	130.5	NA	NA	IS 3025 (Part-14) :2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4.	Colour, Hazen Units	1	5	15	IS 3025 (Part-4) :2021
5.	Turbidity, NTU	0.5	1	5	IS 3025 (Part-10) : 1984
6.	Total Dissolved Solids , mg/l	54	500	2000	IS 3025 (Part-16) : 2023
7.	Alkalinity as CaCO ₃ , mg/l	< 20	200	600	IS 3025 (Part-23) : 2023
8.	Total Hardness as CaCO ₃ , mg/l	< 20	200	600	IS 3025 (Part-21) : 2009
9.	Calcium as Ca, mg/l	< 8	75	200	IS 3025 (Part-40) : 2024
10.	Magnesium as Mg, mg/l	< 5	30	100	IS 3025 (Part-46) : 2023
11.	Chloride as Cl, mg/l	13.90	250	1000	IS 3025 (Part-32) : 1988
12.	Sulphate as SO ₄ , mg/l	2.37	200	400	IS 3025 (Part-24) : 2022
13.	Fluoride as F, mg/l	0.65	1	1.5	APHA 24 th Edition
14.	Nitrate as NO ₃ , mg/l	< 0.5	45	No relaxation	APHA 24 th Edition
15.	Iron as Fe, mg/l	< 0.1	1	No relaxation	IS 3025 (Part-53) : 2024
Remarks: The above tested parameters are within the acceptable limit as per IS 10500:2012 drinking water specification.					

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rules applicable as per the procedure mentioned in RDWSD/WQMSP/DT/01

PRINCIPAL

Rashtrottana Vidya Kendra
Cherkadi Village, Brahmavara Taluk,
Udupi District, Karnataka 576215

-----END OF REPORT-----

CORRESPONDENT
Rashtrottana Vidya Kendra
Cherkadi Village, Brahmavara Taluk
Udupi District Karnataka 576215