

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.: Sample No:-183

Dated: 28/07/25

It is certified that an inspection team headed by Dr. Savitha N A
(Name of Officers with designation) from primary Health Centre Pethri
(Name of Department/ Office) inspected the Rashtrotthana Vidya Kendra
(Name & Address of the school) on 26/07/25 (date of inspection) and
found that the Rashtrotthana Vidya Kendra (Name of school) has
safe drinking water facilities for the students and members of staff of the institution and is
maintaining the hygienic sanitation condition in the school building & the campus as per
norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One Year

Signature with Seal :

Name :

Designation :

Name & Address of the Office / Department PHC Pethri

MEDICAL OFFICER
PRIMARY HEALTH CENTRE, PETHRI
BRAHMAVARA TALUK, UDUPI DIST.-576215

To

(Name & Address of the Institution)

Rashtrotthana Vidya Kendra
Cherkadi, Brahmavara Taluk
Udupi District.-576215

PRINCIPAL

Rashtrotthana Vidya Kendra
Cherkadi Village, Brahmavara Taluk,
Udupi District, Karnataka 576215

Vasanth

CORRESPONDENT

Rashtrotthana Vidya Kendra
Cherkadi Village, Brahmavara Taluk
Udupi District, Karnataka-576215



MANIPAL INSTITUTE OF TECHNOLOGY

MANIPAL

(A constituent unit of MAHE, Manipal)

TEST REPORT

Name and Address of the Customer	Rashtrothana Vidya Kendra, Cherkady Village, Pethri post, Brahmavara
----------------------------------	--

Customer Reference	---	Test Report Number	EE/W39/25
Product/Material	Water	Test Report Date	23/4/25
Sample Identification	Well water	ULR Number	---
Sample Receipt Date	21/4/25	Discipline	Chemical
Date(s) of Testing	21/4/25-23/4/25	Product Group	Water

Test Results

S. No.	Test Parameter	Result	Test Method	Acceptable Limits as per IS 10500:2012	Pass/Fail
01	Colour, Hazen Units	<1.0	IS 3025, Part 4	5	Pass
02	pH at 25 °C	6.4	IS 3025, Part 11	6.5-8.5	Fail
03	Turbidity, NTU	5.0	IS 3025, Part 10	1	Fail
04	Total Dissolved Solids, mg/L	38.0	IS 3025, Part 16	500	Pass
05	Total Alkalinity as CaCO ₃ , mg/L	25.0	IS 3025, Part 23	200	Pass
06	Total Hardness as CaCO ₃ , mg/L	22.0	IS 3025, Part 21	200	Pass
07	Calcium as Ca, mg/l	7.2	IS 3025, Part 40	75	Pass
08	Magnesium as Mg, mg/l	0.97	IS 3025, Part 46	30	Pass
09	Chlorides as Cl, mg/L	5.5	IS 3025, Part 32	250	Pass
10	Total Iron (as Fe), mg/l	<0.1	IS 3025, Part 53	0.3 Max	Pass
11	Ammonical Nitrogen (as N), mg/l	<0.1	IS 3025, Part 34	0.5 Max	Pass
12	Total Coliform	Absent	APHA, 9221 B, 24th Edition 2023	Absent/100ml	Pass
13	Fecal Coliform	Absent	APHA, 9221 B, 24th Edition 2023	Absent/100ml	Pass

Suma

Analyzed by Technician

Checked By	Reviewed and Authorised By	Approved By
<i>[Signature]</i>	<i>[Signature]</i> 25/4/25	<i>[Signature]</i>
Name: Dr. Amar Mohan Shinde	Name: Dr. Sugosh P	Name: Dr. Purushotham G Sarvade
Designation: Testing In-charge	Designation: Laboratory In-charge	Designation: HOD

Environmental Engineering Laboratory

Civil Engg. Department

Manipal Institute of Technology

END OF REPORT-

Notes: Sample not drawn by the laboratory; the tests are performed on customer submitted sample. The results relate only to the items tested. The report shall not be reproduced except in full without approval of the laboratory. All tests are performed in the laboratory's permanent location.

[Signature]

Vasanth

Principal
Manipal Institute of Technology, Manipal 576104, Karnataka, India

dir. + Rashtrothana Vidya Kendra
6040000000@manipal.edu; academic.section@manipal.edu

Cherkadi Village, Brahmavara Taluk,
Udupi District, Karnataka 576215

CORRESPONDENT

Rashtrothana Vidya Kendra
Cherkadi Village, Brahmavara Taluk
Udupi District, Karnataka-576215

PHC /PTR/ 30/2025-2026

PRIMARY HEALTH CENTRE PETHRI
UDUPI DISTRICT UDUPI-576215

DATE:28-07-2025

REPORT OF WATER ANALYSIS (Qualitative Method)						
Sl No	Sample No	Place Of Colletion	Soures Of Water	Date Of Collection and Time	Result and Date	Remarks
22	183	RASTROTHANA VIDYA KENDRA ,CHERKADY VILLAGE	FILTER WATER	26/07/2025 12:05PM	SPP 28/07/2025	

NOTE	S.P.P.	Satisfactory for Portable Purposes.
	N.S.P.P.	Not Satisfactory for Portable Purposes.

N-A Sath
Medical Officer

PHC PETHRI

MEDICAL OFFICER
PRIMARY HEALTH CENTRE, PETHRI
BRAHMAVARA TALUK, UDUPI DIST-576215


PRINCIPAL

Rashtrotthana Vidya Kendra
Cherkadi Village, Brahmavara Taluk,
Udupi District, Karnataka 576215


CORRESPONDENT

Rashtrotthana Vidya Kendra
Cherkadi Village, Brahmavara Taluk
Udupi District, Karnataka-576215